

COMMONWEALTH OF KENTUCKY
BEFORE THE PUBLIC SERVICE COMMISSION

In the Matter of:

THE APPLICATION OF CUMBERLAND FALLS)	
HIGHWAY WATER DISTRICT FOR A DEVIATION)	CASE NO.
FROM 807 KAR 5:066, SECTION 5(4),)	10472
REGARDING WATER STORAGE)	

O R D E R

By letter received November 10, 1988, Cumberland Falls Highway Water District ("Cumberland Water") requested a deviation from 807 KAR 5:066, Section 5(4), which requires a utility to provide water storage to insure a minimum of one day's supply of its average daily water usage.

The Commission, having reviewed the evidence of record and being advised, is of the opinion and finds that:

1. Cumberland Water has identified the need for an additional 500,000-gallon ground water storage tank at an estimated cost of \$445,500.

2. Because of the time needed to plan, finance, and implement a program to increase its water storage facilities, Cumberland Water should be granted a deviation from 807 KAR 5:066, Section 5(4) until January 1, 1992 to bring it within compliance of the Commission's water storage requirements.

IT IS THEREFORE ORDERED that:

1. Cumberland Water be and it hereby is granted a deviation from 807 KAR 5:066, Section 5(4) until January 1, 1992.

2. Cumberland Water shall take all necessary actions to bring its water storage facilities within compliance of the Commission regulations prior to the expiration date of the deviation herein granted.

Done at Frankfort, Kentucky, this 7th day of December, 1988.

PUBLIC SERVICE COMMISSION

Chairman

Robert M. Davis
Vice Chairman

Spencer N. Williams
Commissioner

ATTEST:

Executive Director